


NOTES:

1. SAFE PEDESTRIAN ACCESS MUST BE PROVIDED AROUND WORK AREA.
2. PERMANENT IMPROVEMENTS SHALL BE INSTALLED WITHIN 5 DAYS OF TRENCHING.
3. INSTALL MANUFACTURED CONDUIT CHAIRS BETWEEN CONDUITS IF MORE THAN ONE IN TRENCH.



CITY OF CAMPBELL
PUBLIC WORKS DEPARTMENT

APPROVED BY:

AO
AMY OLAY, P.E.
CITY ENGINEER

DATE:

3/14/22

SIGNAL, LIGHTING &
ELECTRICAL CONDUIT
INSTALLATION - TRENCH LAID
CONDUIT IN UNIMPROVED
AREAS

J./DETAILS/CAD/E17

DETAIL
NO.

E-17

NTS