



**CITY OF CAMPBELL**  
Community Development Department

## Outdoor Seating- ADA Requirements

### Tables

- At least 5% but not less than one dining surface must be accessible.
- Dining surfaces' height should be between 28 inches (minimum) and 34 inches (maximum) above the finished floor.
- A minimum 30-inch-wide clear floor space should allow for a forward approach with knee/toe clearance. The toe clearance must be at least 17 inches under the table, while the knee clearance should be a minimum of 11 inches deep at 9 inches above the floor and 8 inches deep at 27 inches above the floor.

### Accessible Route

- A 36-inch minimum route needs to be maintained throughout the seating area.

### Changes in Level (If Applicable)

- Changes in level of ¼ inch high maximum can be vertical. Changes in level between ¼ inch high minimum and ½ inch high maximum must be beveled with a slope not steeper than 1:2. Any level change greater than ½ inch triggers requirements for a ramp.

### Curb Ramp (If Applicable)

- Running Slope - 1:12 (8.33%) (maximum allowed)
- Cross Slope - 1:48 (2%) (maximum allowed)
- Clear width - 36 inches minimum (measured between handrails where provided)
- Handrails - Handrails are required on both sides of ramps with a rise greater than 6-inches.
- Handrail height - Handrails must be mounted 34 – 38 inches above surface of ramp.
- Handrail extensions - 12-inch extensions must be provided at top and bottom of ramp
- Edge protection - Edge protection along ramp must be provided curbs, barriers, or extended surfaces.
- Landings - Level landings are required at the top and bottom of each run (maximum ramp run is 30 feet)

### Platform (If Applicable)

- Platform on the parking lot should be stable, firm, slip-resistant, and leveled with the sidewalk with a compliant accessible route.

